


1. GROUND SLEEVE MUST BE LEVEL
2. SET 4" ABOVE FINAL GRADE
3. PROVIDE 95% COMPACTION UNDER THE SLEEVE
4. PROVIDE SIDE COMPACTION AROUND SLEEVE WITH 12" APPROVED SLURRY MIX
5. MINIMUM OF 6" WASHED ROCK TO BE INSTALLED UNDER THE GROUND SLEEVE
6. CABLE LENGTH SHALL BE 10' AND MEASURED FROM THE BASE OF THE GROUND SLEEVE
7. THE CABLE DUCT SHALL HAVE 6" EXPOSED IN THE GROUND SLEEVE
8. CABLE SWEEP INTO GROUND SLEEVE MUST BE GRADUAL AND HAVE A 48" RADIUS
9. AN 8' GROUND ROD SHALL BE PLACED IN THE CENTER OF THE OPENING WITH 6" EXPOSED
10. GROUND SLEEVES REQUIRE THE FOLLOWING CLEARANCES
 - a. 10' FROM THE FRONT OF THE UNIT FOR ACCESS
 - b. 3' ON THE SIDES AND BACK FROM STRUCTURES OR LANDSCAPE MATERIAL
 - c. 3' MINIMUM FROM A DRIVING SURFACE WITH THE USE OF BOLLARDS
 - d. 5' FROM A DRIVING SURFACE BEHIND A CURB OR PROTECTIVE FEATURE. RESIDENTIAL DRIVEWAY CLEARANCE MAY BE REDUCED TO 3'
 - e. 10' FROM A DRIVING SURFACE WHERE NO CURB OR PROTECTIVE FEATURE IS PROPOSED
 - f. REFERENCE CLEARANCE AND BOLLARD DETAIL DRAWINGS

	PRIMARY JUNCTION FACILITY GROUND SLEEVE		
	REV. 2	700-11	SCALE: NA
POWER & COMMUNICATIONS	DATE: 10/06.12/07	DRAWN BY: RAWTMF KZ	APPROVAL: