



(ALL SERVICES LARGER THAN 200 AMPS ARE OWNED AND MAINTAINED BY THE CUSTOMER)  
 NOTES - SERVICES 200 AMP OR LESS:

1. METER SHALL BE IN DIRECT LINE-OF-SIGHT WITH THE UTILITY SECONDARY VOLTAGE JUNCTION BOX/J-BOX.
2. METER SHALL BE LOCATED IN THE NEAREST 1/4 OF THE STRUCTURE TO THE SOURCE; NOT FENCED IN.
3. ALL SERVICES 200 AMP OR LESS REQUIRE A LEVER BYPASS METER BASE.
4. ALL ELECTRIC CONDUIT TO BE 2" SCH/40 PVC WITH 24" RADIUS SWEEPS.
5. MICRODUCT CONDUIT (PROVIDED BY LPC) SHALL BE INSTALLED IN THE ELECTRIC TRENCH BY THE BUILDER.
6. THE MICRODUCT SHALL EXTEND 6" ABOVE GRADE AT THE SERVICE ENTRANCE, TIE WRAPPED TO THE ELECTRIC SERVICE CONDUIT AND LAND INSIDE OF THE UTILITY J-BOX LABELED "BROADBAND" ON LID
7. METER HOUSING AND ONE PIPE STRAP SHALL BE ATTACHED WITH AN APPROPRIATE ANCHORING METHOD SO AS NOT TO BECOME DETACHED OVER TIME.
8. METER HOUSING AND CONDUIT SHALL NOT BE ENCLOSED WITHIN ANY STRUCTURES' SIDING OR OTHER MATERIALS AND MUST REMAIN ACCESSIBLE FOR FUTURE MAINTENANCE.
9. USE PVC SLIDER OR EXPANSION COUPLING AT THE ENTRANCE TO THE METER HOUSING.
10. SERVICE LATERAL CONDUCTORS SHALL BE CUT TO A LENGTH THAT ALLOWS THEM TO EXTEND 30" ABOVE THE J-BOX LID OR 48" ABOVE THE TRANSFORMER VAULT AND COILED WITHIN
11. CALL 1-800-922-1987 OR 811 TO OBTAIN UTILITY LOCATES.

METERING SINGLE FAMILY  
 N.T.S.



|                             |
|-----------------------------|
| Print Date: 7/24/2019       |
| File: 2019 SDT TEMPLATE.cel |
| REVISION BY: NOTEBOOMJ      |
| SCALE: NOT TO SCALE         |

|   |  |
|---|--|
| CITY of LONGMONT                        |  |
| 1100 S SHERMAN ST<br>Longmont, CO 80501 | Phone: 303-651-8386<br>FAX: 303-651-8796 |

|        |
|--------|
| DETAIL |
| 700-16 |