



CLEARANCES "X"

- 3' FROM LANDSCAPE MATERIAL
- 5' MINIMUM FROM STRUCTURES
- 3' ADJACENT TO RESIDENTIAL DRIVEWAYS
- 3' MINIMUM FROM A DRIVING SURFACE WITH THE USE OF BOLLARDS
- 5' FROM A DRIVING SURFACE BEHIND A CURB OR PROTECTIVE FEATURE
- 10' FROM A DRIVING SURFACE WHERE NO PROTECTIVE FEATURE IS PROPOSED

NOTES:

1. MAINTAIN MINIMUM CLEARANCES AS NOTED ABOVE
2. BOLLARDS WILL BE INSTALLED AT THE DEVELOPER/OWNER'S EXPENSE WHEN EQUIPMENT IS NOT PROTECTED FROM VEHICULAR TRAFFIC
3. TRANSFORMER LOCATIONS SHALL BE ESTABLISHED BY THE OWNER TO MEET LPC'S MINIMUM CLEARANCES AND ALL FIRE CLEARANCES REQUIRED BY APPLICABLE CODES
4. CLEAR AREAS: 1ST 3' CONTAINING SOD, MULCH, OR ROCKS/COBBLE; MAX. 1.5" DIA.
5. NEXT 7' AREA CAN CONTAIN LOW GROWING PLANTS; MAX. 1 FT. HEIGHT
6. REPOSITIONING EQUIPMENT IS ONLY ALLOWED AT CUSTOMER EXPENSE.
7. ANY DEVIATIONS TO LANDSCAPE MATERIALS WITHIN CLEAR ZONES MUST BE APPROVED BY LPC.

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



CITY OF
LONGMONT
COLORADO

1100 S SHERMAN ST
LONGMONT, CO 80501

**EQUIPMENT
CLEARANCES**

PHONE: 303-651-8386
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved:
File: UG Drawings 2025
DETAIL
700-02