



NOTES:

1. DEPTH: MINIMUM 36", MAX 48" OF COVER, COMPACTED TO 95%
2. EACH END OF THESE CONDUITS MUST BE INSTALLED AT A DEPTH OF 42" AS THEY CROSS LPC'S TRENCH PATH
3. EACH END OF THESE CROSSINGS MUST HAVE A BURIED CABLE MARKER ATTACHED TO IT AND EXTENDED TO THE BACK SIDE OF THE EASEMENT AS SHOWN ABOVE.
4. CONDUIT TIE WRAP MARKERS, PROVIDED BY LPC, ARE TO BE USED AT EACH END OF THE SLEEVES. THEY ARE RED IN COLOR AND HAVE FOOTAGE MARKERS TO INDICATE DEPTH.
5. THE SPECIFIC CABLE MARKERS CAN BE PICKED UP AT LPC'S WAREHOUSE LOCATED AT 1100 S SHERMAN ST
6. SCHEDULE 40 PVC SHALL BE INSTALLED WITH ALL JOINTS HAVING LONG LINE BELL ENDS AND COUPLINGS USING COLD WEATHER GLUE
7. OTHER UTILITY CROSSINGS SHALL BE LOCATED AND MARKED WITH A STAKE. THE STAKE SHALL IDENTIFY THE SIZE AND DEPTH OF THE CROSSING.
8. CROSSINGS FOR COMMUNICATION UTILITIES MAY BE PLACED IN THE SAME TRENCH AS LPC WITH APPROVAL.
9. GAS CROSSINGS SHALL MAINTAIN 5' CLEARANCE FROM ELECTRIC. REFER TO SECTION 701-01-01 SLEEVE INSTALLATION
10. EXTEND OTHER UTILITY CROSSINGS BEYOND THE ELECTRIC EASEMENT
11. FOR TRENCH DETAILS REFER TO 700-04
12. ANY DEVIATIONS TO MAX SLEEVING DEPTH MUST BE APPROVED BY LPC

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



CITY OF
LONGMONT
COLORADO

1100 S SHERMAN ST
LONGMONT, CO 80501

CUSTOMER INSTALLED SLEEVE

PHONE: 303-651-8386
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved:
File: UG Drawings_2025
DETAIL
700-03