



NOTES:

1. J-BOX MUST BE LEVEL AND SET 4" ABOVE FINAL GRADE
2. PROVIDE 95% COMPACTION UNDER AND AROUND THE J-BOX
3. CABLE LENGTH SHALL BE 5' AND MEASURED FROM THE BASE OF THE J-BOX
4. THE CABLE DUCT SHALL HAVE 3" EXPOSED IN THE J-BOX
5. CABLE SWEEPS INTO J-BOX MUST BE GRADUAL AND HAVE A MINIMUM 48" RADIUS
6. TRAFFIC RATED J-BOXES ARE TO BE USED WHEN THE MINIMUM CLEARANCES CANNOT BE MET FROM VEHICLES
7. FOR EQUIPMENT CLEARANCES REFERENCE DETAIL 700-02
8. FOR EQUIPMENT ALIGNMENT ON TRENCH REFERENCE DETAIL 700-05

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



1100 S SHERMAN ST
LONGMONT, CO 80501

**SECONDARY JUNCTION BOX
(J-BOX)**

PHONE: 303-651-8386
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved: 2024
File: UG Drawings_2024.dwg
DETAIL
700-12