

18" TAIL OUT OF STREET LIGHT OR CONCRETE BASE

POLE HEIGHT	HEIGHT	BURY DEPTH
14' PT	11' PT	3.0' PT
20' PT	16' PT	4.0' PT
34.5'	30'	4.5'
39.5'	35'	4.5'

11' TO 35'  
8' TO 30'

NOTES:

1. SET POLE STRAIGHT
2. 95% COMPACTION IS REQUIRED AROUND THE POLE BY USE OF FLOWABLE FILL (LPC SPEC: FLOW FILL)
3. 20' FIBERGLASS POLES SHALL HAVE 12/2 IN DUCT INSTALLED TO THE TOP OF THE POLE
4. 30' - 35' FIBERGLASS POLES SHALL HAVE #12 ROMEX FROM THE SECONDARY J-BOX
5. KEEP THE INSIDE OF THE POLE FREE OF BACKFILL MATERIAL BY TAPING THE OPENINGS CLOSED

24"

12/2 IN TUBE

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



CITY OF  
**LONGMONT**  
COLORADO

1100 S SHERMAN ST  
LONGMONT, CO 80501

**STREET LIGHT POLE**

PHONE: 303-651-8386  
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved: 2024
File: UG Drawings_2024.dwg
<b>DETAIL</b>

**700-13**