



SECONDARY CONDUCTOR AS SPECIFIED FROM ELECTRIC J-BOX

CONCRETE BASE

1. CONCRETE BASE MUST BE LEVEL
2. SET 4" ABOVE FINAL GRADE
3. INSTALL AN 8' GROUND ROD & #4 COPPER
4. PROVIDE 95% COMPACTION UNDER AND AROUND THE CONCRETE BASE
5. FOR STREET LIGHT POLE DETAIL REFERENCE 700-13
6. FOR SECONDARY J-BOX DETAIL REFERENCE 700-12

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



CITY OF
LONGMONT
COLORADO

1100 S SHERMAN ST
LONGMONT, CO 80501

STREET LIGHT BASE

PHONE: 303-651-8386
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved: 2024
File: UG Drawings_2024.dwg
DETAIL

700-14