



10' clearance required for accessible doors on front and back.

Meter housing

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



1100 S SHERMAN ST  
LONGMONT, CO 80501

PM Cabinet Clearances (use notes from updated detail 700-02)

PHONE: 303-651-8386  
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved:
File:
<b>DETAIL</b>
<b>700-22</b>