



PM CABINET DIMS: 72"W x 54"D x 54"H



PM CABINET ISO VIEW. SHOWN ON 3 PHS XFMR PAD.


LINE SIDE BUSHINGS (200A OR 600A)

LOAD SIDE BUSHINGS (200A OR 600A)




PM CABINET TERMINATION COMPARTMENT FRONT VIEW, DOORS OPEN. TYPICAL - SINGLE BUSHING LINE AND LOAD.

CONDUIT BLOCK-OUT - 58"W X 14"D DIVIDED HORIZONTALLY DUE TO BUSHING LAYOUT.




LPC std 3phs xfmr pad - 78"x78"

68"W x 16"D PM CABINET CONDUIT WINDOW.
CABINET CAN MOUNT ON STOCK 3 PHASE TRANSFORMER PAD.



PM CABINET TOP DOWN INTERIOR SECTION VIEW. TYPICAL DIMENSIONS.

Conduit Configuration - LPC, Customer



ELECTRIC SERVICES

CITY OF
LONGMONT
COLORADO

1100 S SHERMAN ST
LONGMONT, CO 80501

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

PRIMARY METERING CABINET CONSTRUCTION DETAIL

PHONE: 303-651-8386
FAX: 303-651-8796

NOT TO SCALE

| |
|----------------|
| Revision #: |
| Approved by: |
| Date Approved: |
| File: |
| DETAIL |
| 700-22B |