



NOTES:

1. ALL CONNECTIONS TO CITY-OWNED FACILITIES MUST BE MADE BY CITY PERSONNEL
2. METER SOCKET AND BREAKER IS REQUIRED AND SHALL MEET NEC REQUIREMENTS PER SIZING OF SERVICE.
3. ALL EQUIPMENT SHALL BE FURNISHED AND INSTALLED BY THE CUSTOMER.
4. TEMPORARY METERING SHALL FOLLOW THE NEC DISCONNECT GUIDELINES.
5. ALL SERVICES 400 AMPS OR LESS, REQUIRE A LEVER OPERATED BYPASS.
6. REFER TO BYPASS DETAILS WITHIN MTR-14, MTR-16 AND MTR-17
7. THE ADDRESS FOR TEMPORARY SERVICES MUST BE PROMINENTLY POSTED FOR SINGLE FAMILY RESIDENTIAL AND A PHENOLIC BADGE FOR COMMERCIAL.
8. REFER TO SECTION 703.01 FOR LABELING REQUIREMENTS
9. REFER TO MTR-1 FOR CONNECTIONS TO J-BOX/TRANSFORMERS
10. REFER TO SECTION 700 FOR ALL OTHER DETAILS

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



1100 S SHERMAN ST  
LONGMONT, CO 80501

TEMPORARY POWER  
1 - 12 MONTHS USE

PHONE: 303-651-8386  
FAX: 303-651-8796

|                             |
|-----------------------------|
| Revision #:                 |
| Approved by:                |
| DATE APPROVED: 2025         |
| File: MTR DRAWINGS_2025.dwg |
| <b>DETAIL</b>               |
| <b>MTR-2</b>                |