



- MINIMUM CLEARANCES;
- 3' FROM TREES
 - 3' HORIZONTAL & 18" VERTICAL FROM COMMUNICATION CABLES/CONDUITS/EQUIPMENT
 - 3' FROM POLES; STREET LIGHT/UTILITY/SIGNAL/ETC.
 - 5' HORIZONTAL & 18" VERTICAL FROM WATER LINES
 - 5' FROM HYDRANTS
 - 5' FROM STRUCTURES (EXCLUDING TRASH ENCLOSURES)
 - 10' HORIZONTAL & 18" VERTICAL FROM STORM/SEWER

NOTE:

1. MINIMUM CLEARANCES, AS NOTED ABOVE, MUST BE MAINTAINED WHEN THE INFRASTRUCTURE'S EXACT LOCATION HAS BEEN DETERMINED VIA POT-HOLING

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE

CITY OF
LONGMONT
COLORADO

1100 S SHERMAN ST
LONGMONT, CO 80501

TRENCH CLEARANCE

PHONE: 303-651-8386
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved:
File: UG Drawings 2025
DETAIL
700-01