



NOTES:

1. MINIMUM TRENCH WIDTH: 8"
2. MINIMUM COVER: 36"
3. MAXIMUM TRENCH DEPTH: 48"
4. THE BOTTOM OF THE TRENCH MUST BE SMOOTH AND CONTINUOUS.
5. ALL TRENCH MUST REMAIN OPEN UNTIL INSPECTED BY LPC.
6. MARKER RIBBON TO BE INSTALLED BEFORE FINAL 12".
7. 95% COMPACTION IS REQUIRED TO A POINT 12" BELOW FINAL GRADE AND 90% FOR THE LAST 12".
8. 95% COMPACTION IS REQUIRED ALL THE WAY TO THE TOP OF THE TRENCH WHEN LOCATED BELOW A HARD SURFACE.
9. THE TRENCH ALIGNMENT SHOWN ABOVE IS FOR SINGLE FAMILY DETACHED LOTS WITH A DETACHED SIDEWALK
10. THE TRENCH ALIGNMENTS FOR ALL OTHER TYPES OF DEVELOPMENTS ARE DETERMINED BY THEIR FINAL ELECTRIC DESIGN PROVIDED BY A LPC FIELD ENGINEER.

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



1100 S SHERMAN ST
LONGMONT, CO 80501

TRENCH DETAIL

PHONE: 303-651-8386
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved:
File: UG Drawings_2025
DETAIL
700-04