



- * COLD SHRINK SHALL BE INSTALLED ON THE ENDS OF ALL PRIMARY CONDUCTORS IN ORDER TO PREVENT THE ENTRANCE OF WATER INTO THE CABLE.
- * ELECTRICAL TAPE DOES NOT OFFER A SUFFICIENT SEAL.
- * WHEN LENGTHS ARE CUT, CABLE ENDS SHOULD BE IMMEDIATELY RESEALED AND SECURED

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



CITY OF
LONGMONT
COLORADO

1100 S SHERMAN ST
LONGMONT, CO 80501

COLD SHRINK INSTALLATION

PHONE: 303-651-8386
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved:
File: UG Drawings_2025
DETAIL
700-08