



NOTES:

1. INSTALL NEXT TO TRANSFORMER WITH THREE FEET MINIMUM CLEARANCE
2. CUSTOMER SHALL FURNISH, INSTALL, OWN, AND MAINTAIN CONCRETE TRANSFORMER PAD, SECONDARY CONNECTION TRAY, SECONDARY CONNECTION PAD, AND SECONDARY CONNECTION CABINET INCLUDING ALL INTERNAL COMPONENTS WITHIN THE SECONDARY CONNECTION CABINET.

ELECTRIC SERVICES

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



CITY OF  
**LONGMONT**  
COLORADO

1100 S SHERMAN ST  
LONGMONT, CO 80501

**SECONDARY CONNECTION CABINET (SCC)  
PART 2**

PHONE: 303-651-8386  
FAX: 303-651-8796

Revision #:
Approved by:
Date Approved: 2024
File: UG Drawings_2024.dwg
<b>DETAIL</b>

**700-19B**