



NOTES:

1. TRANSFORMERS AND TRANSFORMER RATED METER HOUSINGS MUST BE PURCHASED FROM LPC, AT 1100 S. SHERMAN STREET, DURING NORMAL BUSINESS HOURS. PLEASE CALL 303-651-8386 BEFORE COMING IN. THIS WILL ENSURE PERSONNEL IS AVAILABLE TO ISSUE THE EQUIPMENT.
2. TRANSFORMERS AND HOUSINGS SHALL BE MOUNTED BY THE CUSTOMER. ASSOCIATED WIRING WILL BE DONE BY LPC. A MINIMUM 24 HOUR NOTICE MUST BE GIVEN TO LPC AT 303-651-8386 BEFORE A SERVICE CAN BE ENERGIZED.
3. THE METER HOUSING, CT CABINET AND IT'S ASSOCIATED DISCONNECT SHALL BE LOCATED OUTSIDE OF THE BUILDING, ACCESSIBLE TO LPC, AND HAVE AN ENGRAVED PHENOLIC BADGE WITH ADDRESS, A MINIMUM BADGE SIZE = 1"x 2" WITH A MINIMUM TEXT SIZE OF 3/8" IN HEIGHT.
4. METER HOUSING AND CT CABINET SHALL BE NO MORE THAN 15 FT APART FROM EACH OTHER. LPC'S PREFERENCE IS TO HAVE THEM ATTACHED TO EACH OTHER.
5. THE CONDUIT BETWEEN THE CT CABINET AND THE METER HOUSING SHALL BE EMT. THERE SHALL BE A BONDING BUSHING ON THE CONDUIT IN THE CT CABINET AND A PLASTIC OR METAL BUSHING IN THE METER HOUSING SIDE.
6. REFER TO MTR-10 FOR CT CABINET DETAILS
7. REFER TO MTR-13 FOR COMMERCIAL/MIXED USE SWITCHGEAR SPECIFICATIONS
8. REFER TO SECTION 703.01 FOR METERING REQUIREMENTS

CALL 1-800-922-1987 TO OBTAIN UTILITY LOCATES

NOT TO SCALE



1100 S SHERMAN ST
 LONGMONT, CO 80501

CT & PT METERING SPECIFICATIONS

PHONE: 303-651-8386
 FAX: 303-651-8796

Revision #:
Approved by:
DATE APPROVED: 2025
File: MTR DRAWINGS_2025.dwg
DETAIL
MTR-11